

ठाणे महानगरपालिका

दूरध्वनी : २५३३ १२११, २५३३ १५१०
वक्रतुंड प्रयोगशाळा : २५३७ ५७११
वर्तकनगर प्रयोगशाळा : २५८८ १७५२



महानगरपालिका भवन, के. जे. टी. एल., अल्पेडा वकील मार्ग, चंदनवाडी, पांचपाखडी, ठाणे ४०० ६०२.
THE MUNICIPAL CORPORATION OF THE CITY OF THANE

प्रदुषण नियंत्रण कक्ष POLLUTION CONTROL CELL

Recognition of Lab under EPA 1986, notified in the Govt. of India Gazette No. 952
dated 6th November 2002 vide notification No. S. O. 1168 (E) dt. 01.06.02



संदर्भ क्र. / ठा.म.पा./प्र.नि.क्र.
Ref./T.M.C./P.C.C.

Ref./T.M.C./P.C.C./V.Lab - 2762
Sample No. : L1719

दिनांक / / २०
Date : / / 20

Date : 28-Feb-20

Water Analysis Report TMC/PCC/20/RO

Name Of the Organisation : M/S Arunodaya Public School

Address : Vijay Park, Kasarvadavli, GB Road, Thane (W)

E_mail ID : principal@arunodayaschool.com

Date of receiving Sample : 27 February 2020

Sample Collected by : Arunodaya Public School

Type of Water Sample : Drinking Water Sample

Parameters	Results	Limits as per IS 10500
pH	7.30	6.5 - 8.5
Free Residual Chlorine	03	1 ppm
Turbidity	2.0	5 NTU
Chloride	30.0	250 mg/L
Total Hardness	75.00	200 mg/L
Total Coliform Bacteria (MPN)	0.00	0/100 mL
F-Coli	Absent	0/100 mL
E-Coli	Absent	0/100 mL

All results are in ppm except pH.

Remark : The Sample is Microbiologically & Chemically Potable.

Prepared By

Prabhakar Sonawale
Thane Municipal Corporation, Thane

Authorised by

28-Feb-20

Omsatyashiv Paralkar
Thane Municipal Corporation, Thane

This is the analysis report of the Drinking Water Sample Water sample received to our Vakratunda Laboratory on 27/2/2020. This further acknowledges that you have paid the charges Rs. 1205/- vide Receipt No.TMC/HQ/PLC/000777/19-20 dated 27.02.2020